



Certificate of Compliance

Certificate: 70070936

Master Contract: 266855

Project: 70070936

Date Issued: March 30, 2016

Issued to: Carlo Gavazzi Logistics SpA
Via Milano 13
Lainate, Milan 20020
ITALY
Attention: Mr. Claudio Borghi

The products listed below are eligible to bear the CSA Mark shown



Issued by: Anne Drouin
Anne Drouin

PRODUCTS

CLASS – 3211 07 INDUSTRIAL CONTROL EQUIPMENT Miscellaneous Apparatus

Relays, component, open type, magnetically operated, single-pole, RSLM Series, electrical ratings as follows,

Contact	A	HP	Vac	Vdc	Use	°C	Cycles	Material	Pilot Duty
Type 100	6	--	277	--	Gen.	85	20 k	AgSnO2	B300, R300 @ 85°C 6 k cycles, or C300, R300 at room temperature 30 k cycles
	6	--	277	--	Resistive	85	60 k	AgSnO2	
	6	--	--	30	--	85	60 k	AgSnO2	
	8	--	277	--	Resistive	85	10 k	AgSnO2	
Type 001, NO	6	--	277	--	Gen.	85	20 k	AgSnO2	B300, R300 @ 85°C 6 k cycles, or C300, R300 at room temperature 30 k cycles
	6	--	277	--	Resistive	85	30 k	AgSnO2	
	6	--	--	30	--	85	30 k	AgSnO2	
	8	--	277	--	Resistive	85	10 k	AgSnO2	
Type 001, NC	6	--	277	--	Gen.	85	10 k	AgSnO2	B300, R300 @ 85°C 6 k cycles
	6	--	--	30	--	85	10 k	AgSnO2	



Certificate: 70070936

Master Contract: 266855

Project: 70070936

Date Issued: March 30, 2016

Coil: 3 – 60 VDC at surrounding air temperature 85 °C.

NOMENCLATURE:

RSLM	100	-	012					
I	II		III	IV	V	VI	VII	VIII

- I - Series Name: RSLM Series
- II - Contact Configuration:
 - 100 - 1 Form A (NO).
 - 001 - 1 Form C (NO and NC)
- III - Coil Voltage: 12 through 60 V dc
- IV - PCB Vertical
- V - Construction: Sealed
- VI - Contact Material: - AgSnO2
- VII - Contact Plating: No Plating
- VIII - Not used

Note:

These units are open-type devices and certified only for use in complete assemblies where the suitability of the combination is to be determined.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-13 - Industrial Control Equipment

MARKINGS

Company's name, and/or CSA file number 266855, type designation, electrical ratings, serial number or date coding, the CSA Mark appear in a permanent manner on each unit, and any other information as specified in the Certification Report.